



City Of Boulder Colorado Energy Conservation Code Residential Dwelling Ventilation Testing Reporting

Planning and Development Services Building Codes

1101 Arapahoe Ave. Boulder CO 80302

Phone: 303-441-1880

House Address:

Permit #:

Permit Holder:

Phone #:

Testing Date:

Ventilation Flow Measurements:

R403.7.3 Testing. Mechanical ventilation systems shall be tested and verified to provide the minimum ventilation flow rates required by Section R403.7

Bath and Powder room Ventilation flow \geq 50 CFM

System 1 Location	System 2 Location	System 3 Location	System 4 Location	System 5 Location	
Flow Rate	Flow Rate	Flow Rate	Flow Rate	Flow Rate	
					CFM

Whole House Controlled Ventilation System

Balanced Ventilation System
 ASHRAE 62.2 Ventilation Target CFM
 Measured Ventilation Rate CFM

Kitchen Hood ventilation rate is \geq 100 CFM

Measured Ventilation Rate CFM

OR

Exempt from testing:

Kitchen range hoods that are ducted to the outside with 6-inch or larger duct and not more than one 90-degree elbow or equivalent in the duct run.

Testing company:

Tester Name (print):

Signature:

Phone:

Email:

Certification #: