



**City Of Boulder Colorado Energy Conservation Code  
Commercial Dwelling Unit Ventilation Testing Reporting**

Planning and Development Services Building Codes

1101 Arapahoe Ave. Boulder CO 80302

Phone: 303-441-1880

House Address:

Permit #:

Permit Holder:

Phone #:

Testing Date:

**Dwelling Unit Ventilation Flow Measurements:**

C403.7.2.2 Testing. Mechanical ventilation systems shall be tested and verified to provide the minimum ventilation flow rates required by Section C403.7.2

**Bath and Powder room Ventilation/Exhaust flow ≥ 50 CFM**

System 1 Location	System 2 Location	System 3 Location	System 4 Location	System 5 Location
Flow Rate	Flow Rate	Flow Rate	Flow Rate	Flow Rate

CFM

**Whole House Controlled Ventilation System**

Balanced Ventilation System

ASHRAE 62.2 Ventilation Target  CFM

Measured Ventilation Rate  CFM

**Kitchen Hood ventilation rate is ≥ 100 CFM**

Measured Ventilation Rate  CFM

OR

Exempt from testing:

Kitchen range hoods that are ducted to the outside with 6-inch or larger duct and not more than one 90-degree elbow or equivalent in the duct run.

Testing company: \_\_\_\_\_

Tester Name (print): \_\_\_\_\_

Signature: \_\_\_\_\_

Phone: \_\_\_\_\_

Email: \_\_\_\_\_

Certification #: \_\_\_\_\_