



NOTES:

1. SERVICE PIPE SHALL BE TYPE "K" COPPER. FROM MAIN TO STRUCTURE. NO SWEAT JOINTS ALLOWED.

DRAWN BY: JSH

CHECKED BY: RJH

APPROVED BY:
DIRECTOR OF PUBLIC WORKS

CITY OF BOULDER, COLORADO

VALVE BOX

1 1/2" - 2" FIRE
SPRINKLER LINE

ISSUED: JULY 2, 1998

REVISED:

DRAWING NO.

5.21