

NOTES:

- 1. PROVIDE VALVE BOX EXTENSIONS AS NECESSARY TO HAVE FIVE INCHES MINIMUM CLEARANCE BELOW PRESSURE REDUCING VALVE AND SET BOX AND COVER FLUSH WITH FINISH GRADE.
- 2. ALL PVC THREADED FITTINGS SHALL BE COATED WITH LIQUID TEFLON.
- 3. VALVE DETAIL SAME FOR BUBBLERS.

DRAWN BY: JSH CHECKED BY: WGH

APPROVED BY:
DIRECTOR OF PUBLIC WORKS

CITY OF BOULDER, COLORADO

IRRIGATION VALVE ASSEMBLY SPRAY ISSUED: JULY 2, 1998

REVISED: OCT. 17, 2000

DRAWING NO.

3.28