



NOTE: ALL COPPER SHALL BE TYPE "K" HARD
 ALL THREADED CONNECTIONS SHALL BE
 SEALED WITH TEFLON TAPE

DRAWN BY: JSH
 CHECKED BY: WGH

APPROVED BY:
D.A. Rhodes
 DIRECTOR OF PUBLIC WORKS

CITY OF BOULDER, COLORADO

IRRIGATION PRESSURE
 REDUCING VALVE

ISSUED: JULY 2, 1998
 REVISED:

DRAWING NO.
 3.23