



ALL FITTINGS SHALL BE STANDARD CI 125 FLANGED

NOTES:

1. SHOULD ANY SITUATION ARISE OTHER THAN SHOWN CONCERNING THE DEPTH OR OBSTRUCTION OF SERVICE LINE OR THE PLACEMENT OF METER PIT, CALL THE CITY OF BOULDER ROW INSPECTOR.
2. METERS TO BE PLACED IN PUBLIC ROW OR EASEMENT. DO NOT PLACE IN SIDEWALK OR DRIVE.
3. ALL BYPASS VALVES TO BE LOCKED CLOSED.
4. ALL BOLTS MUST BE STAINLESS STEEL AND ALL NUTS MUST BE BRASS.

DRAWN BY: JSH
 CHECKED BY: RJH

APPROVED BY:
 DIRECTOR OF PUBLIC WORKS

CITY OF BOULDER, COLORADO
 STANDARD
 3" AND 4"
 METER SETTING

ISSUED: JULY 2, 1998
 REVISED: OCT. 17, 2000

DRAWING NO.
 5.18C