



NOTES:

1. OPERATING NUT SHALL BE EXTENDED WITHIN 4 FEET OF SURFACE.
2. EXTENSION STEMS REQUIRED WHERE VALVE IS AT DEPTH GREATER THAN 5 FEET.

DRAWN BY: JSH  
 CHECKED BY: RJH

APPROVED BY:  
 DIRECTOR OF PUBLIC WORKS

CITY OF BOULDER, COLORADO

VALVE BOX

ISSUED: JULY 2, 1998  
 REVISED: OCT. 17, 2000

DRAWING NO.

5.11