



CARRIER PIPE NOMINAL DIA.	CASING PIPE		MINIMUM
	MIN. O.D.	MIN. WALL THICK	RUNNER SIZE
4"	12"	0.188"	2" x 4"
6"	16"	0.250"	2" x 4"
8"	18"	0.282"	2" x 4"
12"	22"	0.344"	2" x 4"
16"	28"	0.406"	2" × 6"
20"	32"	0.469"	2" × 6"

DRAWN BY: JSH

CHECKED BY: RJH

APPROVED BY: DIRECTOR OF PUBLIC WORKS

CITY OF BOULDER, COLORADO

PIPE CASING WITH WOOD SKIDS ISSUED: JULY 2, 1998

REVISED: OCT. 17, 2000

DRAWING NO.

4.09B