

6" THICK COLORED AND PATTERNED CONCRETE (VERTICALLY SCORED CONCRETE AS APPROVED BY DIRECTOR OF PUBLIC WORKS)

3' MIN DIMENSIONS MAY VARY SEE PLANS

18" MAX HEIGHT

20% GRADE

EXISTING OR PROPOSED CURB AND GUTTER

COMPACTED SUBGRADE (95% STANDARD PROCTOR DENSITY) REFER TO SPECIFICATIONS. APPLY SOIL STERILANT UNDER PAVEMENT AS SPECIFIED. NO STERILANT SHALL BE PLACED WITHIN 8 FEET OF ANY OPEN PLANTED AREA

FILL WITH SILICONE SEALANT SEALANT SHALL BE ON CDOT APPROVED LIST OF SILICONE SEALANTS

PREFORMED JOINT MATERIAL 3/4" PRE-MOLDED, NON-EXTRUDING AND RESILIENT TYPE EXPANSION JOINT MATERIAL TO MEET ASTM SPECS D-1751 OR D-1752

NOTE: CONTRACTOR SHALL CROWN PAVED SURFACE AT CENTERLINE OF MEDIAN SECTION AND PROVIDE A CURVED TRANSITION. REFER TO PLANS FOR SPECIFIC INSTRUCTIONS.

DRAWN BY: JSH
CHECKED BY: SRW

APPROVED BY:
DIRECTOR OF PUBLIC WORKS

CITY OF BOULDER, COLORADO

**MEDIAN
PAVED COVER**

ISSUED: JULY 2, 1998
REVISED: OCT. 17, 2000

DRAWING NO.
2.41